



**Request for Proposal #21-37340
Light House Tower Renovation Project**

**ADDENDUM #04
Date Issued: March 8, 2021**

This Addendum is issued to all registered plan holders pursuant to the Instructions to Bidders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and issued RFP. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.

All information included in this Addendum, including attachments, shall become part of the Contract Documents and included in the base bid.

Included in Addendum #4: RFI revision (RFI log will reflect the revision from 3.8.21), marked up staging drawing, preliminary design report for glass lantern, and Section 08 8000 Glazing, all of these documents will be posted on our website. <https://ny-rioc.civicplus.com/216/RFPs-Bids>

RFI revision below:

RFI: Structural restraint of top of spiral stair column is not provided, please provide detail.

Response: Provide two (2) 6" x 15lb galvanized steel channels bolted to the perimeter concrete ring beam and spiral stair column/top landing. Allow for bracing every ten (10) feet on height using a 6" x 15 lbs galvanized steel channel bolted to the stair and masonry wall.

All bids due on 3/12/21 at 3pm. No extension of time shall be given.

Late bids will not be accepted.



**Request for Proposal #21-37340
Light House Tower Renovation Project**

**ADDENDUM #04
Date Issued: March 8, 2021**

Receipt of Addendum

(Kindly complete this document and return with your proposal). I have received, read, and considered the information provided in Addendum No.04

Signature

Print Name

Print Title

Print Company Name